SIEMENS

Data sheet

3RH2911-4GA13



auxiliary switch, on the front, 1 NO + 3 NC, 53/54, 61/62, 71/72, 81/82, current path: 1 NO, 1 NC, 1 NC, 1 NC, ring cable lug connection, physically coded, only with contactor relays 3RH2140 and 3RH2441 combinable (according to EN 50011)

product brand name	SIRIUS
product category	Auxiliary switch
product designation	auxiliary switch
design of the product	Can be snapped onto front of 3RH2140/3RH2440 auxiliary switch
product type designation	3RH29
suitability for use	Contactor relay
General technical data	
size of contactor	S00
insulation voltage with degree of pollution 3 at AC rated value	690 V
surge voltage resistance rated value	6 kV
protection class IP on the front	IP00
mechanical service life (operating cycles) typical	10 000 000
electrical endurance (operating cycles) at AC-15 at 230 V typical	200 000
Substance Prohibitance (Date)	10/01/2009
number of NC contacts for auxiliary contacts	
 instantaneous contact 	3
 lagging switching 	0
number of NO contacts for auxiliary contacts	
instantaneous contact	1
 leading contact 	0
number of CO contacts of auxiliary contacts instantaneous contact	0
operational current at AC-15 at 690 V rated value	1 A
operational current of auxiliary contacts at AC-12	
• at 24 V	10 A
• at 230 V	10 A
operational current of auxiliary contacts at AC-14	
• at 125 V	6 A
• at 250 V	6 A
operational current of auxiliary contacts at AC-12 maximum	10 A
operational current of auxiliary contacts at AC-15	
• at 24 V	6 A
• at 230 V	6 A
• at 400 V	3 A
operational current of auxiliary contacts at DC-12	
• at 24 V	10 A
• at 110 V	3 A
• at 220 V	1 A
operational current with 2 current paths in series at DC-12	
• at 24 V rated value	10 A

Confirmat	
Approvals Certificates General Product Approval	
type of electrical connection for auxiliary and control circuit	ring terminal lug connection
onnections/ Terminals	
depth	43.7 mm
width	36 mm
height	37.5 mm
fastening method	snap-on mounting
stallation/ mounting/ dimensions	
contact reliability of auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
 positively driven operation according to IEC 60947-5-1 positively driven operation according to IEC 60947-5-1 	with 3RH2
 mirror contact according to IEC 60947-4-1 positively driven operation according to IEC 60947-5-1 	NO Yes
 product function mirror contact according to IEC 60947-4-1 	No
afety related data	
during storage	-55 +80 °C
during operation	-25 +60 °C
ambient temperature	
mbient conditions	
contact reliability of auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
• at 250 V	0.3 A
• at 220 V	0.3 A
● at 125 V	0.9 A
• at 110 V	1 A
• at 60 V	2 A
• at 48 V	2 A
• at 24 V	6 A
operational current of auxiliary contacts at DC-13	
• at 600 V rated value	0.26 A
• at 440 V rated value	0.5 A
• at 220 V rated value	1.2 A
• at 110 V rated value	3 A
• at 60 V rated value	4.7 A
• at 24 V rated value	10 A
operational current with 3 current paths in series at DC-13	
• at 600 V rated value	0.1 A
• at 440 V rated value	0.2 A
• at 220 V rated value	0.9 A
at 110 V rated value	1.3 A
at 24 V rated value at 60 V rated value	3.5 A
at 24 V rated value	10 A
• at 600 V rated value operational current with 2 current paths in series at DC-13	1.0 A
at 440 V rated value at 600 V rated value	2.5 A 1.8 A
 at 220 V rated value at 440 V rated value 	3.6 A
at 110 V rated value at 220 V rated value	10 A
at 60 V rated value	10 A
• at 24 V rated value	10 A
operational current with 3 current paths in series at DC-12	
at 600 V rated value	0.65 A
• at 440 V rated value	1.3 A
• at 220 V rated value	2 A
• at 110 V rated value	4 A
• at 60 V rated value	10 A

EMC	Functional Safety/Safety of Ma- chinery	Declaration of Conformity		Test Certificates	
RCM	<u>Type Examination Cer-</u> <u>tificate</u>	CE EG-Konf.	UK CA	Special Test Certific- ate	<u>Type Test Certific-</u> ates/Test Report
Marine / Shipping					
ABS	B U REAU VERITAS		Lloyd's Register uis	PRS	RINA
Marine / Shipping	other		Railway		Environment
RMRS R	Confirmation		Vibration and Shock	<u>Type Test Certific-</u> ates/Test Report	Environmental Con- firmations

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

all.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RH2911-4GA13 https://r


Cax online generator


http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RH2911-4GA13


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3RH2911-4GA13

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RH2911-4GA13&lang=en









last modified:

1/27/2022 🖸