SIEMENS

Data sheet

3RT2016-1AP04-3MA0



power contactor, AC-3e/AC-3, 9 A, 4 kW / 400 V, 3-pole, 230 V AC, 50/60 Hz, auxiliary contacts: 2 NO + 2 NC, screw terminal, size: S00, captive auxiliary switch

product brand name SIRIUS product designation Power contactor product type designation 3RT2 General technical data S00 size of contactor S00 product extension No • function module for communication No • auxiliary switch No power loss [W] for rated value of the current 0.9 W • at AC in hot operating state 0.3 W
product type designation 3RT2 General technical data
General technical data size of contactor S00 product extension No • function module for communication No • auxiliary switch No power loss [W] for rated value of the current 0.9 W
size of contactor S00 product extension No • function module for communication No • auxiliary switch No power loss [W] for rated value of the current 0.9 W
product extension No • function module for communication No • auxiliary switch No power loss [W] for rated value of the current 0.9 W
• function module for communication No • auxiliary switch No power loss [W] for rated value of the current 0.9 W
• auxiliary switch No power loss [W] for rated value of the current 0.9 W
power loss [W] for rated value of the current • at AC in hot operating state 0.9 W
• at AC in hot operating state 0.9 W
e at AC in hot operating state per pole
• without load current share typical 4.2 W
insulation voltage
• of main circuit with degree of pollution 3 rated value 690 V
of auxiliary circuit with degree of pollution 3 rated value 690 V
surge voltage resistance
of main circuit rated value 6 kV
of auxiliary circuit rated value 6 kV
maximum permissible voltage for protective separation between coil and main contacts according to EN 60947-1
shock resistance at rectangular impulse
• at AC 6,7g / 5 ms, 4,2g / 10 ms
shock resistance with sine pulse
• at AC 10,5g / 5 ms, 6,6g / 10 ms
mechanical service life (operating cycles)
of contactor typical 10 000 000
of the contactor with added electronically optimized auxiliary switch block typical 5 000 000
of the contactor with added auxiliary switch block typical 10 000 000
reference code according to IEC 81346-2 Q
Substance Prohibitance (Date) 10/01/2009
Ambient conditions
installation altitude at height above sea level maximum 2 000 m
ambient temperature
• during operation -25 +60 °C
• during storage -55 +80 °C
relative humidity minimum 10 %
relative humidity at 55 °C according to IEC 60068-2-30 95 % 95 %
Main circuit
number of poles for main current circuit 3


number of NO contacts for main contacts	3
	5
 operating voltage at AC-3 rated value maximum 	690 V
at AC-3 rated value maximum at AC-3e rated value maximum	690 V
operational current	
at AC-1 at 400 V at ambient temperature 40 °C rated	22 A
value	
• at AC-1	
— up to 690 V at ambient temperature 40 °C rated	22 A
value	
— up to 690 V at ambient temperature 60 °C rated value	20 A
• at AC-3	
— at 400 V rated value	9 A
— at 500 V rated value	7.7 A
— at 690 V rated value	6.7 A
• at AC-3e	
— at 400 V rated value	9 A
— at 500 V rated value	7.7 A
— at 690 V rated value	6.7 A
at AC-4 at 400 V rated value	8.5 A
• at AC-5a up to 690 V rated value	19.4 A
• at AC-5b up to 400 V rated value	7.4 A
• at AC-6a	
— up to 230 V for current peak value n=20 rated value	5.3 A
— up to 400 V for current peak value n=20 rated value	5.3 A
— up to 500 V for current peak value n=20 rated value	5.3 A
— up to 690 V for current peak value n=20 rated value	5 A
● at AC-6a	
— up to 230 V for current peak value n=30 rated value	3.5 A
 — up to 400 V for current peak value n=30 rated value 	3.5 A
— up to 500 V for current peak value n=30 rated value	3.6 A
— up to 690 V for current peak value n=30 rated value	3.3 A
minimum cross-section in main circuit at maximum AC-1 rated value	4 mm ²
operational current for approx. 200000 operating cycles at AC-4	
• at 400 V rated value	4.1 A
• at 690 V rated value	3.3 A
operational current	
 at 1 current path at DC-1 	
— at 24 V rated value	20 A
— at 60 V rated value	20 A
— at 110 V rated value	2.1 A
— at 220 V rated value	0.8 A
— at 440 V rated value	0.6 A
— at 600 V rated value	0.6 A
 with 2 current paths in series at DC-1 	
— at 24 V rated value	20 A
— at 60 V rated value	20 A
— at 110 V rated value	12 A
— at 220 V rated value	1.6 A
— at 440 V rated value	0.8 A
— at 600 V rated value	0.7 A
with 3 current paths in series at DC-1	
— at 24 V rated value	20 A
— at 60 V rated value	20 A
- at 110 V rated value	20 A
- at 220 V rated value	20 A
— at 440 V rated value	1.3 A
- at 600 V rated value	1 A
 at 1 current path at DC-3 at DC-5 	


— at 24 V rated value	20 A
— at 60 V rated value	0.5 A
— at 110 V rated value	0.15 A
 with 2 current paths in series at DC-3 at DC-5 	
— at 24 V rated value	20 A
— at 60 V rated value	5 A
— at 110 V rated value	0.35 A
 with 3 current paths in series at DC-3 at DC-5 	
— at 24 V rated value	20 A
— at 60 V rated value	20 A
— at 110 V rated value	20 A
— at 220 V rated value	1.5 A
— at 440 V rated value	0.2 A
— at 600 V rated value	0.2 A
operating power	
• at AC-3	
— at 230 V rated value	2.2 kW
— at 400 V rated value	4 kW
— at 500 V rated value	4 kW
— at 690 V rated value	5.5 kW
• at AC-3e	
— at 230 V rated value	2.2 kW
— at 400 V rated value	4 kW
— at 500 V rated value	4 kW
— at 690 V rated value	5 kW
operating power for approx. 200000 operating cycles at AC-	
4	
 at 400 V rated value 	2 kW
at 690 V rated value	2.5 kW
operating apparent power at AC-6a	
 up to 230 V for current peak value n=20 rated value 	2 kVA
 up to 400 V for current peak value n=20 rated value 	3.6 kVA
 up to 500 V for current peak value n=20 rated value 	4.6 kVA
 up to 690 V for current peak value n=20 rated value 	5.9 kVA
operating apparent power at AC-6a	
 up to 230 V for current peak value n=30 rated value 	1.3 kVA
 up to 400 V for current peak value n=30 rated value 	2.4 kVA
 up to 500 V for current peak value n=30 rated value 	3.1 kVA
 up to 690 V for current peak value n=30 rated value 	4 kVA
short-time withstand current in cold operating state up to 40 °C	
	455 Aulton minimum groop position and to AC 4 rated value
Imited to 1 s switching at zero current maximum	155 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 5 s switching at zero current maximum 	111 A; Use minimum cross-section acc. to AC-1 rated value
Imited to 10 s switching at zero current maximum	86 A; Use minimum cross-section acc. to AC-1 rated value
Imited to 30 s switching at zero current maximum	66 A; Use minimum cross-section acc. to AC-1 rated value
Imited to 60 s switching at zero current maximum	55 A; Use minimum cross-section acc. to AC-1 rated value
no-load switching frequency	10 000 1/b
• at AC	10 000 1/h
operating frequency	4 000 4/h
• at AC-1 maximum	1 000 1/h
• at AC-2 maximum	750 1/h
• at AC-3 maximum	750 1/h
• at AC-3e maximum	750 1/h
at AC-4 maximum	250 1/h
Control circuit/ Control	
type of voltage of the control supply voltage	AC
control supply voltage at AC	
• at 50 Hz rated value	230 V
at 60 Hz rated value	230 V
operating range factor control supply voltage rated value of magnet coil at AC	
• at 50 Hz	0.8 1.1

• at 60 Hz	0.85 1.1
apparent pick-up power of magnet coil at AC	
• at 50 Hz	27 VA
• at 60 Hz	24.3 VA
inductive power factor with closing power of the coil	
• at 50 Hz	0.8
• at 60 Hz	0.75
apparent holding power of magnet coil at AC	
• at 50 Hz	4.2 VA
• at 60 Hz	3.3 VA
inductive power factor with the holding power of the coil	
at 50 Hz	0.25
• at 60 Hz	0.25
closing delay	
• at AC	9 35 ms
opening delay	
• at AC	4 15 ms
arcing time	10 15 ms
control version of the switch operating mechanism	Standard A1 - A2
Auxiliary circuit	
number of NC contacts for auxiliary contacts instantaneous	2
contact	
number of NO contacts for auxiliary contacts instantaneous	2
contact	40.4
operational current at AC-12 maximum	10 A
operational current at AC-15	
at 230 V rated value	6 A
• at 400 V rated value	3 A
• at 500 V rated value	2 A
• at 690 V rated value	1 A
operational current at DC-12	
• at 24 V rated value	10 A
• at 48 V rated value	6 A
• at 60 V rated value	6 A
• at 110 V rated value	3 A
• at 125 V rated value	2 A
at 220 V rated value	1 A
• at 600 V rated value	0.15 A
operational current at DC-13	
at 24 V rated value	6 A
at 48 V rated value	2 A
at 60 V rated value	2 A
• at 110 V rated value	1A
• at 125 V rated value	0.9 A
• at 220 V rated value	0.3 A
at 600 V rated value	0.1 A
contact reliability of auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
UL/CSA ratings	
full-load current (FLA) for 3-phase AC motor	
• at 480 V rated value	7.6 A
• at 600 V rated value	9 A
yielded mechanical performance [hp]	
• for single-phase AC motor	
— at 110/120 V rated value	0.33 hp
— at 230 V rated value	1 hp
• for 3-phase AC motor	
— at 200/208 V rated value	2 hp
- at 220/230 V rated value	3 hp
— at 460/480 V rated value	5 hp
	·
- at 575/600 V rated value	7.5 hp
contact rating of auxiliary contacts according to UL	A600 / Q600

Short-circuit protection	
design of the fuse link	
 for short-circuit protection of the main circuit 	
 with type of coordination 1 required 	gG: 35A (690V,100kA), aM: 20A (690V,100kA), BS88: 35A (415V,80kA)
— with type of assignment 2 required	gG: 20A (690V,100kA), aM: 16A (690V, 100kA), BS88: 20A (415V, 80kA)
 for short-circuit protection of the auxiliary switch required 	gG: 10 A (500 V, 1 kA)
Installation/ mounting/ dimensions	go. 1077 (000 V, 1107)
	1/190° rotation peoplele on vertical mounting outfoces can be tilted forward and
mounting position	+/-180° rotation possible on vertical mounting surface; can be tilted forward and backward by +/- 22.5° on vertical mounting surface
fastening method	screw and snap-on mounting onto 35 mm DIN rail according to DIN EN 60715
side-by-side mounting	Yes
height	58 mm
width	45 mm
depth	
•	
required spacing	
• with side-by-side mounting	
— forwards	10 mm
— upwards	10 mm
— downwards	10 mm
— at the side	0 mm
 for grounded parts 	
— forwards	10 mm
— upwards	10 mm
— at the side	6 mm
— downwards	10 mm
for live parts	
— forwards	10 mm
— upwards	10 mm
— downwards	10 mm
— at the side	6 mm
Connections/ Terminals	0 mm
type of electrical connection	
• for main current circuit	screw-type terminals
for auxiliary and control circuit	screw-type terminals
 at contactor for auxiliary contacts 	Screw-type terminals
of magnet coil	Screw-type terminals
type of connectable conductor cross-sections for main contacts	
• solid	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), 2x 4 mm²
 solid or stranded 	2x (0,5 1,5 mm²), 2x (0,75 2,5 mm²), 2x 4 mm²
 finely stranded with core end processing 	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
connectable conductor cross-section for main contacts	
• solid	0.5 4 mm²
• stranded	0.5 4 mm²
 finely stranded with core end processing 	0.5 2.5 mm²
connectable conductor cross-section for auxiliary contacts	
solid or stranded	0.5 4 mm²
 finely stranded with core end processing 	0.5 2.5 mm ²
type of connectable conductor cross-sections	
for auxiliary contacts	$2 \times (0.5 - 1.5 \text{ mm}^2) 2 \times (0.75 - 0.5 \text{ mm}^2) 2 \times 4 \text{ mm}^2$
 — solid or stranded 	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), 2x 4 mm²
for the store of the state of the store of t	
- finely stranded with core end processing	2x (0.5 1.5 mm ²), 2x (0.75 2.5 mm ²)
for AWG cables for auxiliary contacts	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²) 2x (20 16), 2x (18 14), 2x 12
for AWG cables for auxiliary contacts AWG number as coded connectable conductor cross	
for AWG cables for auxiliary contacts AWG number as coded connectable conductor cross section	2x (20 16), 2x (18 14), 2x 12
for AWG cables for auxiliary contacts AWG number as coded connectable conductor cross section for main contacts	2x (20 16), 2x (18 14), 2x 12 20 12
for AWG cables for auxiliary contacts AWG number as coded connectable conductor cross section for main contacts for auxiliary contacts	2x (20 16), 2x (18 14), 2x 12
for AWG cables for auxiliary contacts AWG number as coded connectable conductor cross section o for main contacts o for auxiliary contacts	2x (20 16), 2x (18 14), 2x 12 20 12
for AWG cables for auxiliary contacts AWG number as coded connectable conductor cross section o for main contacts o for auxiliary contacts	2x (20 16), 2x (18 14), 2x 12 20 12
for AWG cables for auxiliary contacts AWG number as coded connectable conductor cross section for main contacts for auxiliary contacts Safety related data	2x (20 16), 2x (18 14), 2x 12 20 12
for AWG cables for auxiliary contacts AWG number as coded connectable conductor cross section for main contacts for auxiliary contacts Safety related data product function	2x (20 16), 2x (18 14), 2x 12 20 12 20 12

proportion of danger					
	ous failures				
 with low deman 	d rate according to SN 319	20 40 %			
 with high deman 	nd rate according to SN 319	920 73 %			
failure rate [FIT] with lo	ow demand rate according	to SN 31920 100 F	IT		
T1 value for proof test 61508	interval or service life acco	rding to IEC 20 a			
	n the front according to I	EC 60529 IP20			
-	the front according to IEC		-safe, for vertical contac	t from the front	
suitability for use		iniger			
•		Yes			
safety-related sy	0	fes			
ertificates/ approvals General Product App					
æ	Confirmation		ŝ	KC	
S					tHL
EMC	Functional Safety/Safety of Ma- chinery	Declaration of Confor	mity	Test Certificates	
RCM	Type Examination Cer- tificate	CE EG-Konf.	UK CA	Type Test Certific- ates/Test Report	Special Test Certific- ate
Marine / Shipping					
ABS	BUREAU VERITAS		Hoyds Kegister uis	PRS	RINA
Marine / Shipping	other			Railway	Environment
	<u>Confirmation</u>		<u>Confirmation</u>	Vibration and Shock	Environmental Con- firmations
RMRS					
RMRS urther information					
	to exit the Russian mark	ket (see here).			
Siemens has decided https://press.siemens.co Siemens is working of Please contact your lo EAC relevant market (Information on the pa	d to exit the Russian mark com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s octher than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi	ersteinens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus	C certification if you inter	nd to import or offer to supp	bly these products to an
Siemens has decided https://press.siemens.co Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dow https://www.siemens.co	com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10	existemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875	C certification if you inter	nd to import or offer to supp	oly these products to an
Siemens has decided https://press.siemens.co Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dow https://www.siemens.co Industry Mall (Online	com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10 e ordering system)	e/siemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875 Brochures,)	C certification if you inter sia or Belarus).	nd to import or offer to supp	bly these products to an
Siemens has decided https://press.siemens.c Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dov https://www.siemens.c Industry Mall (Online https://mall.industry.sie Cax online generator	com/global/en/pressrelease on the renewal of the curr cal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10 e ordering system) emens.com/mall/en/en/Cata r	e/siemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875 Brochures,)	C certification if you inter sia or Belarus). <u>16-1AP04-3MA0</u>		bly these products to ar
Siemens has decided https://press.siemens.c Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dov https://www.siemens.c Industry Mall (Online https://mall.industry.sie Cax online generator http://support.automati	com/global/en/pressrelease on the renewal of the curr cal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10 e ordering system) emens.com/mall/en/en/Cata r ion.siemens.com/WW/CAX	e/siemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875 Brochures,) alog/product?mlfb=3RT20 order/default.aspx?lang=e	C certification if you inter sia or Belarus). <u>16-1AP04-3MA0</u>		bly these products to ar
Siemens has decided https://press.siemens.c Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dov https://www.siemens.c Industry Mall (Online https://mall.industry.sie Cax online generator http://support.automati Service&Support (Ma	com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10 e ordering system) emens.com/mall/en/en/Cata r ion.siemens.com/WW/CAX anuals, Certificates, Chara	existemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875 Brochures,) alog/product?mlfb=3RT20 order/default.aspx?lang=e acteristics, FAQs,)	C certification if you inter sia or Belarus). <u>16-1AP04-3MA0</u>		bly these products to ar
Siemens has decided https://press.siemens.c Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dov https://www.siemens.c Industry Mall (Online https://mall.industry.sie Cax online generator http://support.automati Service&Support (Ma https://support.industry	com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10 o ordering system) emens.com/mall/en/en/Cata r ion.siemens.com/WW/CAX anuals, Certificates, Chara y.siemens.com/cs/ww/en/ps	existemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875 Brochures,) alog/product?mlfb=3RT20 order/default.aspx?lang=e acteristics, FAQs,) s/3RT2016-1AP04-3MA0	C certification if you inter sia or Belarus). <u>16-1AP04-3MA0</u> en&mlfb=3RT2016-1AP(04-3MA0	bly these products to ar
Siemens has decided https://press.siemens.co Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dov https://www.siemens.co Industry Mall (Online https://mall.industry.sie Cax online generator http://support.automati Service&Support (Ma https://support.industry Image database (prov	com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10 e ordering system) emens.com/mall/en/en/Cata r ion.siemens.com/WW/CAX anuals, Certificates, Chara	e/siemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875 Brochures,) alog/product?mlfb=3RT20 order/default.aspx?lang=e acteristics, FAQs,) s/3RT2016-1AP04-3MA0 on drawings, 3D models,	C certification if you inter sia or Belarus). <u>16-1AP04-3MA0</u> en&mlfb=3RT2016-1AP(, device circuit diagran	04-3MA0	bly these products to ar
Siemens has decided https://press.siemens.c. Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dov https://www.siemens.c Industry Mall (Online https://mall.industry.sie Cax online generator http://support.automati Service&Support (Ma https://support.industry Image database (proo http://www.automation	com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10 e ordering system) emens.com/mall/en/en/Cata r ion.siemens.com/WW/CAX anuals, Certificates, Chara y.siemens.com/cs/ww/en/ps duct images, 2D dimensio	e/siemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875 Brochures,) alog/product?mlfb=3RT20 order/default.aspx?lang=e acteristics, FAQs,) s/3RT2016-1AP04-3MA0 on drawings, 3D models, le.aspx?mlfb=3RT2016-1/	C certification if you inter sia or Belarus). <u>16-1AP04-3MA0</u> en&mlfb=3RT2016-1AP(, device circuit diagran	04-3MA0	bly these products to ar
Siemens has decided https://press.siemens.co Siemens is working of Please contact your lo EAC relevant market (Information on the pa https://support.industry Information- and Dov https://www.siemens.co Industry Mall (Online https://mall.industry.sie Cax online generator http://support.automati Service&Support (Ma https://support.industry Image database (proo http://www.automation Characteristic: Trippi https://support.industry	com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E ackaging y.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, E com/ic10 e ordering system) emens.com/mall/en/en/Cata r ion.siemens.com/WW/CAX anuals, Certificates, Chara y.siemens.com/cs/ww/en/ps duct images, 2D dimension i.siemens.com/bilddb/cax_com/	e/siemens-wind-down-russ rent EAC certificates. tatus of validity of the EAC EAEU member states Rus ew/109813875 Brochures,) alog/product?mlfb=3RT20 order/default.aspx?lang=6 acteristics, FAQs,) s/3RT2016-1AP04-3MA0 on drawings, 3D models, le.aspx?mlfb=3RT2016-1/ ot-through current s/3RT2016-1AP04-3MA0/	C certification if you inter sia or Belarus). <u>16-1AP04-3MA0</u> en&mlfb=3RT2016-1AP(, device circuit diagran AP04-3MA0⟨=en char	04-3MA0	oly these products to ar





last modified:

2/10/2023 🖸