SIEMENS

Data sheet

3RT2023-1AV04



power contactor, AC-3e/AC-3, 9 A, 4 kW / 400 V, 3-pole, 400 V AC, 50 Hz, auxiliary contacts: 2 NO + 2 NC, screw terminal, size: S0, removable auxiliary switch

product brand name	SIRIUS
product designation	Power contactor
product type designation	3RT2
General technical data	
size of contactor	SO
product extension	
 function module for communication 	No
auxiliary switch	No
power loss [W] for rated value of the current	
 at AC in hot operating state 	0.6 W
 at AC in hot operating state per pole 	0.2 W
 without load current share typical 	7.6 W
insulation voltage	
 of main circuit with degree of pollution 3 rated value 	690 V
 of auxiliary circuit with degree of pollution 3 rated value 	690 V
surge voltage resistance	
 of main circuit rated value 	6 kV
 of auxiliary circuit rated value 	6 kV
maximum permissible voltage for protective separation between coil and main contacts according to EN 60947-1	400 V
shock resistance at rectangular impulse	
• at AC	7,5g / 5 ms, 4,7g / 10 ms
shock resistance with sine pulse	
• at AC	11,8g / 5 ms, 7,4g / 10 ms
mechanical service life (operating cycles)	
 of contactor typical 	10 000 000
 of the contactor with added electronically optimized auxiliary switch block typical 	5 000 000
 of the contactor with added auxiliary switch block typical 	10 000 000
reference code according to IEC 81346-2	Q
Substance Prohibitance (Date)	10/01/2009
Ambient conditions	
installation altitude at height above sea level maximum	2 000 m
ambient temperature	
 during operation 	-25 +60 °C
during storage	-55 +80 °C
relative humidity minimum	10 %
relative humidity at 55 °C according to IEC 60068-2-30 maximum	95 %
Main circuit	
number of poles for main current circuit	3


number of NO contacts for main contacts	3
operating voltage	
at AC-3 rated value maximum	690 V
 at AC-3e rated value maximum 	690 V
operational current	
• at AC-1 at 400 V at ambient temperature 40 °C rated	40 A
value	
• at AC-1	
— up to 690 V at ambient temperature 40 °C rated value	40 A
— up to 690 V at ambient temperature 60 °C rated	35 A
value	
• at AC-3	
— at 400 V rated value	9 A
— at 500 V rated value	9 A
— at 690 V rated value	9 A
• at AC-3e	
— at 400 V rated value	9 A
— at 500 V rated value	9 A
— at 690 V rated value	9 A 0 5 A
at AC-4 at 400 V rated value	8.5 A
at AC-5a up to 690 V rated value	35.2 A
• at AC-5b up to 400 V rated value	7.4 A
• at AC-6a	44.4.4
— up to 230 V for current peak value n=20 rated value	11.4 A
 — up to 400 V for current peak value n=20 rated value — up to 500 V for current peak value n=20 rated value 	11.4 A 9.1 A
— up to 500 V for current peak value n=20 rated value	9A
• at AC-6a	SA .
 up to 230 V for current peak value n=30 rated value 	7.6 A
— up to 200 V for current peak value n=30 rated value	7.6 A
— up to 500 V for current peak value n=30 rated value	6.1 A
— up to 690 V for current peak value n=30 rated value	6.1 A
minimum cross-section in main circuit at maximum AC-1 rated	10 mm ²
value	
operational current for approx. 200000 operating cycles at AC-4	
at 400 V rated value	4.1 A
at 690 V rated value	3.3 A
operational current	
 at 1 current path at DC-1 	
— at 24 V rated value	35 A
— at 60 V rated value	20 A
— at 110 V rated value	4.5 A
— at 220 V rated value	1 A
— at 440 V rated value	0.4 A
— at 600 V rated value	0.25 A
• with 2 current paths in series at DC-1	
— at 24 V rated value	35 A
— at 60 V rated value	35 A
— at 110 V rated value	35 A
— at 220 V rated value	5 A
— at 440 V rated value	1 A
— at 600 V rated value	0.8 A
 with 3 current paths in series at DC-1 	
— at 24 V rated value	35 A
— at 60 V rated value	35 A
— at 110 V rated value	35 A
— at 220 V rated value	35 A
— at 440 V rated value	2.9 A
— at 600 V rated value	1.4 A
 at 1 current path at DC-3 at DC-5 	


— at 24 V rated value	20 A
— at 60 V rated value	5 A
— at 220 V rated value	1 A
— at 440 V rated value	0.09 A
— at 600 V rated value	0.06 A
 with 2 current paths in series at DC-3 at DC-5 	
— at 24 V rated value	35 A
— at 60 V rated value	35 A
— at 110 V rated value	15 A
— at 220 V rated value	3 A
— at 440 V rated value	0.27 A
— at 600 V rated value	0.16 A
 with 3 current paths in series at DC-3 at DC-5 	
— at 24 V rated value	35 A
— at 60 V rated value	35 A
— at 110 V rated value	35 A
— at 220 V rated value	10 A
— at 440 V rated value	0.6 A
— at 600 V rated value	0.6 A
operating power	
• at AC-2 at 400 V rated value	4 kW
• at AC-3	
— at 230 V rated value	2.2 kW
— at 400 V rated value	4 kW
— at 500 V rated value	4 kW
— at 690 V rated value	7.5 kW
• at AC-3e	
— at 230 V rated value	2.2 kW
— at 400 V rated value	4 kW
— at 500 V rated value	4 kW
— at 690 V rated value	7.5 kW
operating power for approx. 200000 operating cycles at AC-	
4	
• at 400 V rated value	2 kW
at 690 V rated value	2.5 kW
operating apparent power at AC-6a	
 up to 230 V for current peak value n=20 rated value 	4.5 kVA
 up to 400 V for current peak value n=20 rated value 	7.8 kVA
 up to 500 V for current peak value n=20 rated value 	7.8 kVA
 up to 690 V for current peak value n=20 rated value 	10.7 kVA
operating apparent power at AC-6a	
• up to 230 V for current peak value n=30 rated value	3 kVA
• up to 400 V for current peak value n=30 rated value	5.2 kVA
• up to 500 V for current peak value n=30 rated value	5.2 kVA
up to 690 V for current peak value n=30 rated value	7.2 kVA
short-time withstand current in cold operating state up to 40 °C	
 limited to 1 s switching at zero current maximum 	170 A; Use minimum cross-section acc. to AC-1 rated value
-	
 limited to 5 s switching at zero current maximum limited to 10 s switching at zero current maximum 	170 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 10 s switching at zero current maximum limited to 30 s switching at zero current maximum 	140 A; Use minimum cross-section acc. to AC-1 rated value 104 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 30 s switching at zero current maximum limited to 60 s switching at zero current maximum 	88 A; Use minimum cross-section acc. to AC-1 rated value
	oo A, ose minimum cross-section act. to AC-1 rated Value
no-load switching frequency • at AC	5 000 1/h
operating frequency	1 000 1/h
• at AC-1 maximum	
• at AC-2 maximum	1 000 1/h
at AC-3 maximum	1 000 1/h
at AC-3e maximum	1 000 1/h
at AC-4 maximum	300 1/h
Control circuit/ Control	


type of voltage of the control supply voltage	AC
control supply voltage at AC	
at 50 Hz rated value	400 V
operating range factor control supply voltage rated value of magnet coil at AC	
• at 50 Hz	0.8 1.1
apparent pick-up power of magnet coil at AC	
• at 50 Hz	65 VA
inductive power factor with closing power of the coil	
• at 50 Hz	0.82
apparent holding power of magnet coil at AC	
• at 50 Hz	7.6 VA
inductive power factor with the holding power of the coil	
• at 50 Hz	0.25
closing delay	
• at AC	8 40 ms
opening delay	
• at AC	4 16 ms
arcing time	10 10 ms
control version of the switch operating mechanism	Standard A1 - A2
Auxiliary circuit	
number of NC contacts for auxiliary contacts instantaneous contact	2
number of NO contacts for auxiliary contacts instantaneous contact	2
operational current at AC-12 maximum	10 A
operational current at AC-15	
at 230 V rated value	6 A
• at 400 V rated value	3 A
• at 500 V rated value	2 A
at 690 V rated value	1 A
operational current at DC-12	
• at 24 V rated value	10 A
at 48 V rated value	6 A
• at 60 V rated value	6 A
• at 110 V rated value	3 A
• at 125 V rated value	2 A
at 220 V rated value	1 A
• at 600 V rated value	0.15 A
operational current at DC-13	
• at 24 V rated value	6 A
at 48 V rated value	2 A
at 60 V rated value	2 A
at 110 V rated value	1A
at 125 V rated value	0.9 A
at 220 V rated value	0.3 A
at 600 V rated value	0.1 A
contact reliability of auxiliary contacts UL/CSA ratings	1 faulty switching per 100 million (17 V, 1 mA)
full-load current (FLA) for 3-phase AC motor	
at 480 V rated value	7.6 A
at 400 V rated value at 600 V rated value	9 A
yielded mechanical performance [hp]	
for single-phase AC motor	
- at 110/120 V rated value	1 hp
— at 230 V rated value	1 hp
• for 3-phase AC motor	
- at 200/208 V rated value	2 hp
— at 220/230 V rated value	3 hp
— at 460/480 V rated value	5 hp
— at 575/600 V rated value	7.5 hp
	· • •


contact rating of auxiliary contacts according to UL	A600 / Q600
Short-circuit protection	A0007 Q000
design of the fuse link	
for short-circuit protection of the main circuit	
- with type of coordination 1 required	gG: 63A (690V,100kA), aM: 32A (690V,100kA), BS88: 63A (415V,80kA)
— with type of assignment 2 required	gG: 25A (690V,100kA), aM: 22A (690V,100kA), B000: 05A (415V,00kA) gG: 25A (690V,100kA), aM: 20A (690V,100kA), BS88: 25A (415V,80kA)
 for short-circuit protection of the auxiliary switch required 	gG: 10 A (500 V, 1 kA)
Installation/ mounting/ dimensions	99. 10 A (500 V, 1 A)
	1/ 400° relation possible on vertical mounting surfaces can be tilted forward and
mounting position	+/-180° rotation possible on vertical mounting surface; can be tilted forward and backward by +/- 22.5° on vertical mounting surface
fastening method	screw and snap-on mounting onto 35 mm DIN rail according to DIN EN 60715
 side-by-side mounting 	Yes
height	85 mm
width	45 mm
depth	141 mm
required spacing	
 with side-by-side mounting 	
— forwards	10 mm
— upwards	10 mm
— downwards	10 mm
— at the side	0 mm
 for grounded parts 	
— forwards	10 mm
— upwards	10 mm
— at the side	6 mm
— downwards	10 mm
• for live parts	
— forwards	10 mm
— upwards	10 mm
— downwards	10 mm
— at the side	6 mm
Connections/ Terminals	
type of electrical connection	
 for main current circuit 	screw-type terminals
 for auxiliary and control circuit 	screw-type terminals
 at contactor for auxiliary contacts 	Screw-type terminals
of magnet coil	Screw-type terminals
type of connectable conductor cross-sections for main contacts	
• solid	2x (1 2.5 mm²), 2x (2.5 10 mm²)
solid or stranded	2x (1 2.5 mm ²), 2x (2.5 10 mm ²)
 finely stranded with core end processing 	2x (1 2.5 mm²), 2x (2.5 6 mm²), 1x 10 mm²
connectable conductor cross-section for main contacts	
• solid	1 10 mm²
• stranded	1 10 mm²
 finely stranded with core end processing 	1 10 mm²
connectable conductor cross-section for auxiliary contacts	
solid or stranded	0.5 2.5 mm²
 finely stranded with core end processing 	0.5 2.5 mm²
type of connectable conductor cross-sections	
for auxiliary contacts	
— solid or stranded	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
 finely stranded with core end processing 	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
 for AWG cables for auxiliary contacts 	2x (20 16), 2x (18 14)
AWG number as coded connectable conductor cross section	
for main contacts	16 8
 for auxiliary contacts 	20 14
Safety related data	
product function	
 mirror contact according to IEC 60947-4-1 	Yes
 positively driven operation according to IEC 60947-5-1 	No


B10 value with high d	lemand rate according to SN	21020 450	000			
		31920 450	000			
proportion of dange	rous failures					
 with low deman 	nd rate according to SN 3192	20 40 %	6			
 with high dema 	and rate according to SN 319	20 73 %	6			
failure rate [FIT] with	low demand rate according t	o SN 31920 100	FIT			
T1 value for proof tes 61508	t interval or service life acco	rding to IEC 20 a	1			
protection class IP of	on the front according to I	EC 60529 IP20	IP20			
touch protection on	the front according to IEC	60529 finge	er-safe, for vertical contact	from the front		
suitability for use						
 safety-related s 	switching OFF	Yes				
ertificates/ approval	S					
General Product Ap	proval					
		<u>Confirmation</u>	(h) u	KC	EHC	
EMC	Functional Safety/Safety of Ma- chinery	Declaration of Confo	ormity	Test Certificates		
RCM	Type Examination Cer- tificate	UK CA	CE EG-Konf.	Type Test Certific- ates/Test Report	<u>Special Test Certific</u> <u>ate</u>	
Marine / Shipping						
44		å	Lloyds			
ABS	BUREAU	DNV		RINA	RMRS	
ABS	BUREAU VERITAS	DNV	Railway	Environment	RMRS	
other Confirmation		Confirmation		Environment Environmental Con- firmations	RMRS	
<u>Confirmation</u> rther information Siemens has decide	ed to exit the Russian mark	et (see here).	Railway Vibration and Shock	Environmental Con-	RMARS	
Confirmation Inther information Siemens has decide https://press.siemens Siemens is working Please contact your le EAC relevant market nformation on the p https://support.indust	com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E packaging ry.siemens.com/cs/ww/en/vie	et (see here). /siemens-wind-down-ru ent EAC certificates. tatus of validity of the E/ AEU member states Ru ew/109813875	Railway Vibration and Shock Ssian-business AC certification if you interve	Environmental Con- firmations	bly these products to a	
Confirmation inther information Siemens has decident https://press.siemens Siemens is working Please contact your le EAC relevant market nformation on the p intps://support.industr nformation- and Do https://www.siemens. ndustry Mall (Online	.com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the s (other than the sanctioned E backaging ry.siemens.com/cs/ww/en/vie wnloadcenter (Catalogs, E com/ic10 e ordering system)	et (see here). /siemens-wind-down-ru ent EAC certificates. tatus of validity of the E/ :AEU member states Ru ew/109813875 irochures,)	Railway Vibration and Shock ssian-business AC certification if you intend ssia or Belarus).	Environmental Con- firmations	PMARS Products to a	
Confirmation Inther information Siemens has decide https://press.siemens Siemens is working Please contact your le EAC relevant market information on the p https://support.industry information- and Do https://www.siemens. ndustry Mall (Onlin- https://mall.industry.s Cax online generato	.com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the si (other than the sanctioned E packaging ry.siemens.com/cs/ww/en/vie wnloadcenter (Catalogs, E com/ic10 e ordering system) iemens.com/mall/en/en/Cata or	et (see here). /siemens-wind-down-ru ent EAC certificates. iatus of validity of the E/ iAEU member states Ru w/109813875 ;rochures,)	Railway Vibration and Shock Ssian-business AC certification if you intervisia or Belarus). 2023-1AV04	Environmental Con- firmations	Ply these products to a	
Confirmation rther information Siemens has decide https://press.siemens Siemens is working Please contact your le EAC relevant market nformation on the p https://support.industr nformation- and Do https://www.siemens. ndustry Mall (Onlin https://mall.industry.s Cax online generato http://support.automa Service&Support (M	.com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the si (other than the sanctioned E packaging ry.siemens.com/cs/ww/en/vie wnloadcenter (Catalogs, E com/ic10 e ordering system) iemens.com/mall/en/en/Cata or tion.siemens.com/WW/CAXe lanuals, Certificates, Chara	et (see here). /siemens-wind-down-ru ent EAC certificates. tatus of validity of the E/ tatus of validity of the the tatus of validity of the the tatus of validity of the the tatus of validity of the tatus of vali	Railway Vibration and Shock Ssian-business AC certification if you intervisia or Belarus). 2023-1AV04	Environmental Con- firmations	Dly these products to a	
Confirmation Confirmation Siemens has decide https://press.siemens Siemens is working Please contact your le EAC relevant market nformation on the p https://support.industr nformation- and Do https://www.siemens. Industry Mall (Onlim- https://www.siemens. Cax online generato http://support.automa Service&Support (M https://support.industr mage database (pro- http://www.automatio	.com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the si (other than the sanctioned E backaging ry.siemens.com/cs/ww/en/vie wnloadcenter (Catalogs, E com/ic10 e ordering system) iemens.com/mall/en/en/Cata or tion.siemens.com/WW/CAX/ lanuals, Certificates, Chara ry.siemens.com/cs/ww/en/ps boduct images, 2D dimension n.siemens.com/bilddb/cax_d	et (see here). /siemens-wind-down-rui ent EAC certificates. tatus of validity of the E/ AEU member states Ru ew/109813875 srochures,) log/product?mlfb=3RT2 order/default.aspx?lange icteristics, FAQs,) /3RT2023-1AV04 in drawings, 3D model e.aspx?mlfb=3RT2023-	Railway Vibration and Shock ssian-business AC certification if you intendissia or Belarus). 023-1AV04 =en&mlfb=3RT2023-1AV02 s, device circuit diagram	Environmental Con- firmations	bly these products to a	
Confirmation Inther information Siemens has decident Siemens is working Please contact your lu EAC relevant market information on the p https://support.industr information- and Do https://www.siemens. industry Mall (Online https://www.siemens. Cax online generator intp://support.automa Service&Support (Industr mage database (pro- http://www.automation Characteristic: Tripp	.com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the si (other than the sanctioned E backaging ry.siemens.com/cs/ww/en/vie wnloadcenter (Catalogs, E com/ic10 e ordering system) iemens.com/mall/en/en/Cata or tion.siemens.com/WW/CAX/ lanuals, Certificates, Chara ry.siemens.com/cs/ww/en/ps oduct images, 2D dimension n.siemens.com/bilddb/cax_d ping characteristics, I ² t, Le	et (see here). /siemens-wind-down-ru: ent EAC certificates. tatus of validity of the E/ AEU member states Ru ew/109813875 srochures,) log/product?mlfb=3RT2 prder/default.aspx?lange incteristics, FAQs,) /3RT2023-1AV04 in drawings, 3D model e.aspx?mlfb=3RT2023- t-through current	Railway Vibration and Shock ssian-business AC certification if you intendissia or Belarus). 023-1AV04 =en&mlfb=3RT2023-1AV02 s, device circuit diagram	Environmental Con- firmations	bly these products to a	
Confirmation Inther information Siemens has decident Siemens is working Please contact your li EAC relevant market Information on the p https://support.industr Information- and Do https://www.siemens. Industry Mall (Onlinent https://www.siemens. Industry Mall (Onlinent https://support.automa Service&Support (IM Service&Support (Industri mage database (pro- https://support.industri mage database (pro- https://support.industri Mattabase (pro- https://support.industri Mattab	.com/global/en/pressrelease on the renewal of the curr ocal Siemens office on the si (other than the sanctioned E backaging ry.siemens.com/cs/ww/en/vie wnloadcenter (Catalogs, E com/ic10 e ordering system) iemens.com/mall/en/en/Cata or tion.siemens.com/WW/CAX/ lanuals, Certificates, Chara ry.siemens.com/cs/ww/en/ps boduct images, 2D dimension n.siemens.com/bilddb/cax_d	et (see here). /siemens-wind-down-ru: ent EAC certificates. tatus of validity of the E/ /AEU member states Ru ew/109813875 srochures,) log/product?mlfb=3RT2 prder/default.aspx?lange incteristics, FAQs,) /3RT2023-1AV04 on drawings, 3D model e.aspx?mlfb=3RT2023- t-through current /3RT2023-1AV04/char	Railway Vibration and Shock ssian-business AC certification if you intendissia or Belarus). 2023-1AV04 een&mlfb=3RT2023-1AV04 s, device circuit diagram 1AV04⟨=en	Environmental Con- firmations	bly these products to a	











last modified:

2/10/2023 🖸