



中国国家强制性产品认证证书

证书编号: 2003010305073833

委托人名称、地址

欧姆龙自动化(中国)有限公司
上海市外高桥保税区爱都路253号4号楼第4层B1-1部位 200131

生产者(制造商)名称、地址

欧姆龙株式会社
京都市下京区盐小路通堀川东入

生产企业名称、地址

东乡电机制作所株式会社
鸟取县东伯郡汤梨浜町大字門田906-1

产品名称和系列、规格、型号

安全门开关

DABS(详见附件);Ui:600V;Ith:20A;AC-15;Ue/Te:400V/2A,115V/6A;IP67

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期:2015年06月15日

有效期至:2020年06月15日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期:2003年08月01日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1151244



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010305073833

NAME AND ADDRESS OF THE APPLICANT

OMRON INDUSTRIAL AUTOMATION (CHINA) CO., LTD
4TH FLOOR OF NO.4 BUILDING, NO.253 AI DU ROAD, WAIGAOQIAO FREE TRADE
ZONE, SHANGHAI, CHINA (200131)

NAME AND ADDRESS OF THE MANUFACTURER

OMRON Corporation
SHIOKOJI HORIKAWA, SHIMOGYO-KU, KYOTO, 600-8530 JAPAN

NAME AND ADDRESS OF THE FACTORY

Togo Electronics Works Co., Ltd
906 1 Kadota, Yurihama cho, Tohaku - gun, Tottori - ken, 689-0736,
JAPAN

NAME, MODEL AND SPECIFICATION

Safety Door Switch

D4BS;Ui:600V;Ich:20A;AC-15;Ue/Ie:400V/2A, 115V/6A; IP67

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jun.15, 2015 Date of expiry: Jun.15, 2020

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug.01, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:


Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1151244



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2003010305073833

纸号: 1151244

型号的解释:

D 4 B S - □ □ □ S □ - □ □ - □
1 2 3 4 5 6 7 8

1. 基本型号

D 4 B S: 安全门开关

2. 导线孔尺寸

1	: P G 13.5	(1 个导线孔)
2	: G 1 / 2	(1 个导线孔)
3	: 1 / 2 - 1 4 N P T	(1 个导线孔)
4	: M 20	(1 个导线孔)
5	: P G 13.5	(3 个导线孔)
6	: G 1 / 2	(3 个导线孔)
7	: 1 / 2 - 1 4 N P T	(3 个导线孔)
8	: M 20	(3 个导线孔)

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2003010305073833

纸号: 1151244

型号的解释: (续)

3. 内置开关

1	: 1 NC / 1 NO / 1 Change-over 接点 (慢速)	
5	: 1 NC / 1 NO 接点	(慢速)
6	: 1 NC / 1 NO 接点	(慢速) 镀金接点
A	: 2 NC 接点	(慢速)
B	: 2 NC 接点	(慢速) 镀金接点

4. 头部安装方向

F	: 正面及上面
B	: 背面及上面
L	: 左面及上面
R	: 右面及上面

5. 连接器

空白: 无连接器

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2003010305073833

纸号: 1151244

型号的解释: (续)

6. 指示灯

空白: 无指示灯

LD: 有指示灯(AC/DC10~115V)

LE: 有指示灯(AC250V)

7. 外包装颜色

空白: 标准色

R : 红色

8. 客户编码

空白: 标准产品

: 面向特定客户 (最大可显示 6 位数字或字母。外观、内部结构均与标准品相同)

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

