



PRODUCT CERTIFICATE

No.: CQC12001080419

NAME AND ADDRESS OF THE APPLICANT

Schaffner EMV AG
Nordstrasse 11, CH-4542 Luterbach, Switzerland

NAME AND ADDRESS OF THE MANUFACTURER

Schaffner EMC Ltd.
Northern Region Industrial Estate 67 Moo 4 Tambol Ban Klang Amphur Muang Lamphun 51000 Thailand

NAME AND ADDRESS OF THE FACTORY

Schaffner EMC Ltd. (V013631)
Northern Region Industrial Estate 67 Moo 4 Tambol Ban Klang Amphur Muang Lamphun 51000 Thailand

NAME, MODEL AND SPECIFICATION

Filter
See Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T15287-1994 GB/T15288-1994

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC11-471141-2016.

Date of issue: Jun.19,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug.29,2012

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>



产品认证证书

证书编号: CQC12001080419

申请人名称及地址

Schaffner EMV AG
Nordstrasse 11, CH-4542 Luterbach, 瑞士

制造商名称及地址

夏弗纳电磁兼容有限公司(泰国)
Northern Region Industrial Estate 67 Moo 4 Tambol Ban Klang Amphur Muang
Lamphun 51000 泰国

生产企业名称及地址

夏弗纳电磁兼容有限公司(泰国) (V013631)
Northern Region Industrial Estate 67 Moo 4 Tambol Ban Klang Amphur Muang
Lamphun 51000 泰国

产品名称和系列、规格、型号

滤波器

见附件

产品标准和技术要求

GB/T15287-1994 GB/T15288-1994

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-471141-2016认证规则的要求, 特发此证。

发证日期: 2016年06月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年08月29日

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



产品认证证书

附录:

第 1 页 共 1 页

证书编号: CQC12001080419

纸号: 81554

额定参数为: 110/250VAC 50-60Hz 1A /10A 40℃

气候类别: 25/085/21

型号/Type	电流 [A]	电感量 mH	X 电容 μ F	Y 电容 nF	电阻 M Ω
FN28x - 1-....	1	7.5	0.22	2 * 2.2	1
FN28xE- 1-....	1	7.5	0.22	2 * 2.2	1
FN28x - 2-....	2	2.0	0.22	2 * 2.2	1
FN28xE-2-....	2	2.0	0.22	2 * 2.2	1
FN28x -4-....	4	1.0	0.22	2 * 2.2	1
FN28xE-4-....	4	1.0	0.22	2 * 2.2	1
FS4951-4-06	4	2.0	0.22	2 * 2.2	1
FN28x - 6-....	6	0.45	0.22	2 * 2.2	1
FN28xE- 6-....	6	0.45	0.22	2 * 2.2	1
FN28x -10-....	10	0.34	0.22	2 * 2.2	1

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>