


Relay actuators & Status indicating modules



Panels for
electrical
distribution




Analogue override module - Auto/Hand (0...10)V

- Analogue output module intended to provide, by the selection switch on the front panel, a (0...10)V output, automatically or by hand.
- With the selector switch in position "A" (Automatic) the (0...10)V signal is derived from the controller.
- In position "H" (Hand) the controller signal is ignored and the (0...10)V signal is derived directly from the potentiometer setting on the facia of the module
- The level of the (0...10)V output signal is displayed by 3 green LEDs, set at > 25%, > 50% and > 75%.
- 24 V AC/DC supply
- 35 mm rail (EN 60715) mounting

Application examples:

- permits the direct control of proportional valves under exceptional circumstances or where the automatic controller has failed

Wiring diagram

For outline drawing see page 9

(0...10)V Signal specification (terminal Y_in)

Input control signal	V DC	0...10 (Imax 20 mA - short-circuit protected)
Green LED 25%		> 2.5 V
Green LED 50%		> 5 V
Green LED 75%		> 7.5 V

Feedback output specification (terminals 53-54)

Output configuration		1 NO (SPST-NO)
Maximum / Minimum current	mA	100/10
Rated voltage	V AC/DC	24

Supply & Input specification


Nominal voltage (U_N)	V AC (50/60 Hz)	24
	VDC	24
Rated power AC/DC	VA (50 Hz)/W	0.9/0.7
Operating range	AC	(0.8...1.1)U_N
	DC	(0.8...1.1)U_N

Technical data

Ambient temperature range	°C	-20...+50
Protection category		IP 20
Approvals (according to type)		  

19.50.0.024.0000

- Analogue output (0...10)V, plus 1 feedback output contact
- 17.5 mm wide
- LED indicator



53-54 feedback to the controller signaling Auto-operation


Y_{in}-A2 variable (0...10)V DC from the controller

Hand (0...10)V DC value set by the potentiometer

Power relay module 16 A

- Suitable for Lamps load
- AgSnO₂ contacts for heavy duty, high inrush current loads
- DC supply (12 or 24 V)
- LED indicator
- Reinforced insulation between supply and contacts
- Cadmium Free contacts
- 35 mm rail (EN 60715) mounting

Wiring diagram



For outline drawing see page 9


Contact specification

Contact configuration		1 CO (SPDT)
Rated current/Maximum peak current	A	16/30 (120 A - 5 ms)
Rated voltage/ Maximum switching voltage	V AC	250/440
Rated load AC1	VA	4000
Rated load AC15 (230 V AC)	VA	750
Nominal lamp rating (230 V):		
incandescent/halogen W		2000
fluorescent tubes with electronic ballast W		1000
fluorescent tubes with electromagnetic ballast W		750
CFL W		400
230 V LED W		400
halogen or LED with electronic ballast W		400
halogen or LED with electromagnetic ballast W		800
Minimum switching load	mW	300 (5 V / 5 mA)
Standard contact material		AgSnO ₂
Coil specification		
Nominal voltage (U _N)	V DC	12 - 24
Rated power DC	W	0.5
Operating range		(0.8 ... 1.1)U _N
Technical data		
Mechanical life AC/DC	cycles	10 · 10 ⁶
Electrical life at rated load AC1	cycles	80 · 10 ³
Operate/release time	ms	12/8
Ambient temperature range	°C	-20...+50
Protection category		IP 20
Approvals (according to type)		  

19.91.9.0xx.4000



- 1 Pole changeover contact
- 17.5 mm



Switching actuator with KNX technology - 16 A

Type 19.3K.9.030.4300

- 6 relays for 3 roller shutters
- Logically interlocked outputs
- Slats management (3 different types)

B

Type 19.6K.9.030.4300

- Compact and powerful switching actuator with 6 relay outputs
- 6 output contacts rated 16 A 250 V AC, individually configurable NO or NC
- Time functions (ON, OFF, Blink, Staircase)
- Independent logic and analog functions for each output (AND, OR, XOR, THRESHOLD, WINDOW)
- LED status indicator for each output
- Scenario Management
- Output control area for manual control
- Supply voltage via KNX bus
- 35 mm rail (EN 60715) mounting

19.3K/19.6K
Screw terminal



19.3K.9.030.4300



- Bistable relay ENEC approved (Maximum peak current up to 120 A)
- Suitable for up to 3 roller shutters
- Slats management

19.6K.9.030.4300



- Bistable relay ENEC approved (Maximum peak current up to 120 A)
- Suitable for lamp loads

For outline drawing see page 9

Contact specification

Contact configuration (via ETS)	V AC	NO - NC	NO - NC
Rated current/Maximum peak current	A	16/120 (5 ms)	16/120 (5 ms)
Rated voltage/ Maximum switching voltage	V	250/400	250/400
Rated load AC1	VA	4000	4000
Rated load AC15 (230 V AC)	VA	750	750
Single phase motor rating (230 V AC)	kW	0.55	0.55
Nominal lamp rating (230 V):			
incandescent/halogen W		2000	2000
fluorescent lamp with electronic ballast W		1000	1000
fluorescent lamp with electromagnetic ballast W		750	750
CFL W		400	400
LED 230 V W		400	400
halogen or LV LED with electronic ballast W		400	400
halogen or LV LED with electromagnetic ballast W		800	800

Standard contact material

AgSnO₂AgSnO₂

Supply specification

Type of BUS		KNX	KNX
Supply voltage	VDC	30	30
Nominal consumption	mA	15	15

Technical data

Mechanical life	cycles	10 · 10 ⁶	10 · 10 ⁶
Electrical life at rated load AC1	cycles	100 · 10 ³	100 · 10 ³
Ambient temperature range	°C	-5...+45	-5...+45
Protection category		IP 20	IP 20
Approvals (according to type)		CE UK CA	CE UK CA

Ordering information

Example: 19 series Auto/Off/On override module, 1 CO (SPDT) 10 A contact, 24 V AC/DC supply.


1	9	.	2	1	.	0	.	0	2	4	.	0	0	0	0
Series															
Type															
21 = Auto/Off/On output module, 11.2 mm															
50 = Analogue override module (0...10)V															
91 = Power relay module															
3K = KNX roller shutters actuator, 3 channels 16 A															
6K = KNX generic loads actuator, 6 poles 16 A															
Supply version															
0 = AC (50/60 Hz)/DC															
9 = DC															
Supply voltage															
012 = 12 V															
024 = 24 V															
030 = KNX Bus															
Codes / Module width															
19.21.0.024.0000/11.2 mm															
19.50.0.024.0000/17.5 mm															
19.91.9.012.4000/17.5 mm															
19.91.9.024.4000/17.5 mm															
19.3K.9.030.4300/70 mm															
19.6K.9.030.4300/70 mm															

Technical data

Insulation		19.21	19.50	19.91
Dielectric strength (V AC)	between supply and contacts	3000	—	4000
	between open contacts	1000	—	1000
	between supply and feedback output	2000	1500	—
EMC specifications				
Type of test		Reference standard	19.21/91	19.50
Electrostatic discharge	contact discharge	EN 61000-4-2	4 kV	
	air discharge	EN 61000-4-2	8 kV	
Radiated electromagnetic field (80...1000 MHz)		EN 61000-4-3	30 V/m	
Fast transients (burst) (5-50 ns, 5 kHz)		EN 61000-4-4	4 kV	
Voltage pulses (1.2/50 µs)	common mode	EN 61000-4-5	2 kV	1 kV
	differential mode	EN 61000-4-5	1 kV	0.5 kV
Terminals		19.21/3K/6K	19.50/91	
Screw torque	Nm	0.5	0.8	
Max. wire size	mm ²	solid cable	stranded cable	solid cable
		1 x 6 / 2 x 2.5	1 x 4 / 2 x 1.5	1 x 6 / 2 x 4
	AWG	1 x 10 / 2 x 14	1 x 12 / 2 x 16	1 x 10 / 2 x 12
Wire strip length	mm	7	9	


Wiring diagrams - Application examples

Type 19.21




B

Type 19.50




In selector position A (Automatic) the (0...10)V controller variable is transferred via Y_{in} - A2 and Y_{out} to the end process.
In selector position H (Hand) the (0...10)V value set by the regulator is transferred via Y_{out} to the end process.

Type 19.3K




Type 19.6K




Outline drawings


Type 19.21
Screw terminal




Type 19.50
Screw terminal




Type 19.91
Screw terminal



Type 19.3K/19.6K
Screw terminal



Accessories

060.48

B

Sheet of marker tags (CEMBRE Thermal transfer printers) for 19.21/50/91/3K/6K types,
(48 tags) 6 x 12 mm

060.48



019.01

Identification tag, for 19.50 types, plastic, 1 tag, 17 x 25.5 mm

019.01



020.01

Adaptor for panel mounting, for 19.21/50/91 types, plastic, 17.5 mm wide

020.01

Application notes

Intervention Modules

The demand for security apparatus, heating, air conditioning or efficient energy use in offices, hotels, and private homes or in industrial space is growing constantly, leading to the installation of increasingly complex electronic systems. But what happens if these systems malfunction and a qualified service technician will only be available in a few hours, or even days?

With the use of carefully installed intervention modules, a trained caretaker or security guard can be in a position to recognize interruptions in service, and by manual intervention perform the necessary override actions to maintain system operation until a repair can be effected.

Digital Override control module

Auto-Off-On output module (Type 19.21)

Many processes or systems are automatically controlled by an electronic control system or by a Programmable Logic Controller. In the event of an electronic system malfunction it is important, in order to avoid damage or downtime, to plan for the possibility of controlling the process manually. An Auto-Off-On Module can provide this, located between the output of the electronic system (Controller) and the process to be controlled (End Process) - bypassing the malfunctioning control unit in a planned way. For malfunctioning electronic systems, the process to be controlled can be manually switched On or Off, as needed, using the switch on the front of the unit. Under healthy functioning of the electronic system, the switch is left in the Auto position. In this configuration the process is controlled by the normal functioning of the electronic system and its output. It may be important to know (remotely) if the process is being controlled manually or automatically, in which case the feedback contact on the Auto-Off-On module 19.21 can provide this.

Analogue Override control module

Analogue output module (0...10)V (Type 19.50)

This module can be installed where there is need to give a manually adjustable analog signal (0...10)V priority over an analog signal from a electronic control unit or PLC, or to override and replace a malfunctioning signal.

The Analogue override module provides, by the selection switch on the front panel, a (0...10)V output signal either generated automatically or by hand. With the selector switch in position "A" (Automatic) the (0...10)V signal at Y_{out} -A2 is derived from the controller signal applied to terminals Y_{in} -A2. In position "H" (Hand) the controller signal is ignored and the (0...10)V signal is derived directly from the potentiometer setting on the module front panel.

Operation in switch position H is indicated by a blinking yellow LED, and by the opening of contact 51-52 – which could be used to report the override condition to the central control room.

The level of the (0...10)V output signal is displayed by 3 green LEDs, set at > 25%, > 50% and > 75%

B

