SIEMENS

Data sheet

6GK5205-3BD00-2TB2



SCALANCE XB205-3 managed Layer 2 IE Switch 5x IEC 62443-4-2 certified; 10/100 Mbit/s RJ45 ports 3x MM FO SC-port 1x console port, diagnostics LED redundant power supply; IEC 62443-4-2 certified; temperature range 0 °C to +60 °C; DIN-rail mounting; default EtherNet/IP.

product type designation SCALANCE XB205-3 transfer rate 10 Mbit/s, 100 Mbit/s number of ports / maximum 8 interfaces / for communication / maximum configuration for modular devices 1 number of electrical ports / maximum 5 number of optical ports / maximum 3 interfaces / for communication / integrated 3 number of electrical connections 5; RJ45 number of 100 Mbit/s SC ports 3 of r multimode 3 interfaces / other 3 number of electrical connections 5; RJ45 of romultimode 3 interfaces / other 1 of operator console 1 of operator console 1 of or power supply 1		
transfer rate 10 Mbit/s, 100 Mbit/s number of ports / maximum 8 interfaces / for communication / maximum configuration for modular devices number of electrical ports / maximum 5 number of optical ports / maximum 3 interfaces / for communication / integrated 3 number of electrical connections 6 • for network components or terminal equipment 5; RJ45 number of 100 Mbit/s SC ports 3 • for multimode 3 interfaces / other 1 number of electrical connections 1 • for multimode 1 • for multimode 1 • for operator console 1 • for operator purposes 1		
number of ports / maximum 8 interfaces / for communication / maximum configuration for modular devices number of electrical ports / maximum 5 number of optical ports / maximum 3 interfaces / for communication / integrated 3 number of electrical connections 6; RJ45 of or network components or terminal equipment 5; RJ45 number of 100 Mbit/s SC ports 3 of or multimode 3 interfaces / other 1 number of electrical connections 1		
interfaces / for communication / maximum configuration for modular devices number of electrical ports / maximum 5 number of optical ports / maximum 3 interfaces / for communication / integrated 3 number of electrical connections 5; RJ45 of or network components or terminal equipment 5; RJ45 number of 100 Mbit/s SC ports 3 of or multimode 3 interfaces / other 1 number of electrical connections 1		
number of electrical ports / maximum 5 number of optical ports / maximum 3 interfaces / for communication / integrated 3 number of electrical connections for network components or terminal equipment for multimode for multimode interfaces / other number of electrical connections for operator console for operator console for management purposes 1 		
number of optical ports / maximum 3 interfaces / for communication / integrated		
interfaces / for communication / integrated number of electrical connections • for network components or terminal equipment 5; RJ45 number of 100 Mbit/s SC ports • for multimode 3 interfaces / other number of electrical connections • for operator console • for management purposes		
number of electrical connections 5; RJ45 • for network components or terminal equipment 5; RJ45 number of 100 Mbit/s SC ports 3 • for multimode 3 interfaces / other 1 number of electrical connections 1 • for operator console 1 • for management purposes 1		
• for network components or terminal equipment 5; RJ45 number of 100 Mbit/s SC ports 3 • for multimode 3 interfaces / other 1 number of electrical connections 1 • for operator console 1 • for management purposes 1		
number of 100 Mbit/s SC ports 3 • for multimode 3 interfaces / other 1 number of electrical connections 1 • for operator console 1 • for management purposes 1		
• for multimode 3 interfaces / other number of electrical connections • for operator console • for management purposes 1		
interfaces / other number of electrical connections • for operator console 1 • for management purposes 1		
number of electrical connections 1 • for operator console 1 • for management purposes 1		
for operator console for management purposes 1		
• for management purposes 1		
• for power supply 1		
···· b - · · · · · · · · · · · · · · · ·		
type of electrical connection		
for operator console RJ11		
for management purposes RJ45		
supply voltage, current consumption, power loss		
product component / connection for redundant voltage supply Yes		
type of voltage / 1 / of the supply voltage DC		
• supply voltage / 1 / rated value 24 V		
power loss [W] / 1 / rated value 7.2 W		
• supply voltage / 1 / rated value 19.2 28.8 V		
consumed current / 1 / maximum 0.3 A		
• type of electrical connection / 1 / for power supply 6-pole terminal block		
product component / 1 / fusing at power supply input Yes		
ambient conditions		
ambient temperature		
• during operation 0 60 °C		
• during storage -40 +70 °C		
• during transport -40 +70 °C		
relative humidity		
at 25 °C / without condensation / during operation / 95 % maximum		
protection class IP IP20		
design, dimensions and weights		
design Box		

width	80 mm
height	
depth	109 mm
net weight	0.35 kg
material / of the enclosure	0.35 kg Plastic
fastening method	
35 mm top hat DIN rail mounting	Yes
product features, product functions, product components / ger	
cascading in the case of a redundant ring / at reconfiguration time of $<\!\!\sim\!\!0.3\!\!\sim\!\!s$	50
cascading in cases of star topology	any (depending only on signal propagation time)
product functions / management, configuration, engineering	
product function	
• CLI	Yes
 web-based management 	Yes
MIB support	Yes
 TRAPs via email 	Yes
configuration with STEP 7	Yes
RMON	Yes
• port mirroring	Yes
multiport mirroring	No
• CoS	Yes
PROFINET IO diagnosis	Yes
PROFINET conformity class	В
product function / switch-managed	Yes
telegram length / for Ethernet / maximum	1522 byte
protocol / is supported	
• Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• DCP	Yes
• LLDP	Yes
EtherNet/IP	Yes
SNMP v1	Yes
• SNMP v2	Yes
• SNMP v3	Yes
 IGMP (snooping/querier) 	Yes
identification & maintenance function	
 I&M0 - device-specific information 	Yes
 I&M1 - higher level designation/location designation 	Yes
product functions / diagnostics	
product function	
port diagnostics	Yes
statistics Packet Size	Yes
 statistics packet type 	Yes
error statistics	Yes
• SysLog	Yes
loopback diagnostics	Yes
product functions / VLAN	
product function	
• VLAN - port based	Yes
product functions / DHCP	
product function	
DHCP client	Yes
product functions / redundancy	
product function	
ring redundancy	Yes
High Speed Redundancy Protocol (HRP)	Yes
 high speed redundancy protocol (HRP) with redundancy 	Yes
	100

manager	Ver
 high speed redundancy protocol (HRP) with standby redundancy 	Yes
protocol / is supported / Media Redundancy Protocol (MRP)	Yes
product function	
media redundancy protocol (MRP) with redundancy	Yes
manager	
 Media Redundancy Protocol Interconnection (MRP-I) 	Yes
redundancy procedure STP	Yes
redundancy procedure RSTP	Yes
 redundancy procedure RSTP+ 	Yes
Parallel Redundancy Protocol (PRP)/operation in the	No
PRP-network	
passive listening	Yes
protocol / is supported	
• LACP	Yes
product functions / security	
product function	
ACL - MAC-based	Yes
ACL - port/MAC-based	Yes
• IEEE 802.1x (radius)	Yes
broadcast/multicast/unicast limiter	Yes
broadcast blocking	Yes
protocol / is supported	
SSH	Yes
• SSL	Yes
product functions / time	
product function	
	Vee
SICLOCK support	Yes
NTP-client	Yes
SNTP client	Yes
protocol / is supported	
• SNTP	Yes
standards, specifications, approvals	
standard	
• for FM	FM3611: Class 1, Division 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4, FM19US0167X
• for FM	FM19US0167X
 for FM for emitted interference	FM19US0167X EN 61000-6-4 (Class A)
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code e according to IEC 81346-2	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code eaccording to IEC 81346-2 eaccording to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code eaccording to IEC 81346-2 eaccording to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C,
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code eaccording to IEC 81346-2 eaccording to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone e from CSA and UL	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C,
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T5, E240480
for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T5, E240480 Yes Ex nA IIC T4 Gc
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T5, E240480 Yes
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T5, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7)
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T5, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7) EN 61000-6-2, EN 61000-6-4
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T5, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7) EN 61000-6-2, EN 61000-6-4 Yes
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standards, specifications, approvals / bazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes; 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T5, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7) EN 61000-6-2, EN 61000-6-4
 for FM for emitted interference for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 reference code according to IEC 81346-2 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking certificate of suitability / RoHS conformity standards, specifications, approvals / hazardous environments standards, specifications, approvals / hazardous environments standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard CCC / for hazardous zone according to GB standard / as marking for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick 	FM19US0167X EN 61000-6-4 (Class A) EN 61000-6-2 Yes KF KFE Yes Yes 2011/65/EU EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T5, E240480 Yes Ex nA IIC T4 Gc E240480 (NWHP, NWHP7) EN 61000-6-2, EN 61000-6-4 Yes

 to web page: selection aid TIA Selection Tool 	http://www.siemens.com/tia-selection-tool
 to website: Industrial communication 	http://www.siemens.com/simatic-net
• to website: Industry Mall	https://mall.industry.siemens.com
 to website: Information and Download Center 	http://www.siemens.com/industry/infocenter
 to website: Image database 	http://automation.siemens.com/bilddb
 to website: CAx-Download-Manager 	http://www.siemens.com/cax
• to website: Industry Online Support	https://support.industry.siemens.com
security information	
security information	Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

7/1/2023 🖸